






ANNUAL FIRE DAMPER DROP TEST CERTIFICATE					
Client:		XYZ Hotel Group		Contract No: CAC/1624	
Site Address:		National Account			
Expires Date:		May 2025		Result: PASS	
Description of Damper Location		10th Floor Riser cupboard between rooms 1008 & 1009		Damper ID: 0602	
					
Is the fire damper in a fire compartment?		Yes		If not where? N/A	
Drop Test Conducted?		Yes		If Not why? N/A	
Fire Damper Left Set?		Yes		If Not Why? N/A	
Fire Damper Type:		Motorised		Ventilation System Type: Supply	
Damper state when found					
				Set	
Damper Triggered					
				Pass	
Damper Reset:					
				Pass	
Notes and / or remedial work					
Compliance Engineer Name:		T H Best			
Date of Test:		29/04/2024			